



NOTES

KEY

- SIZEWELL C MAIN DEVELOPMENT SITE BOUNDARY
- DEMARCATION LINE
- COMBINED DISCHARGE OUTFALL LOCATION
- INTAKE TUNNEL
- COOLING WATER OUTFALL TUNNEL
- COOLING WATER DISCHARGE OUTFALL LOCATION
- COOLING WATER INTAKE LOCATION

PLUME EXTENT OF HYDRAZINE OF THE 95TH PERCENTILE

- >=1ng/l
- >=2ng/l
- >=3ng/l
- >=4ng/l
- >=5ng/l

NOT PROTECTIVELY MARKED

COPYRIGHT
Reproduced from Ordnance Survey map with the permission of Ordnance Survey on behalf of the controller of Her Majesty's Stationary Office © Crown Copyright (2019). All Rights reserved. NNB GenCo 0100060408.
© CEFAS; Royal HaskoningDHV, 2019.



DOCUMENT:
SIZEWELL C
SHADOW HRA REPORT
CHAPTER 5
SCREENING OF POTENTIAL EFFECTS

DRAWING TITLE:
95TH PERCENTILE OF HYDRAZINE
CONCENTRATIONS AT THE SURFACE.
THIS IS AFTER THE RELEASE OF 69 NGL-1
OF HYDRAZINE IN PULSES OF 2.32H FROM
SIZEWELL C.

DRAWING NO:
FIGURE 5.7

DATE: JAN 2020 DRAWN: J.T. SCALE: 1:45,000 @A3

SCALE BAR
0 0.5 1 1.5 2 KM