

Name	Source type	Lw dB(A)	Time histogram	63Hz dB(A)	125Hz dB(A)	250Hz dB(A)	500Hz dB(A)	1kHz dB(A)	2kHz dB(A)	4kHz dB(A)	8kHz dB(A)
EM DIESEL GEN BUILDING 1 IN1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 1 IN2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 1 IN3	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 1 IN4	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 1 OUT1	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 1 OUT2	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 1 OUT3	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 1 OUT4	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 2 IN1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 2 IN2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 2 IN3	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 2 IN4	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 2 OUT1	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 2 OUT2	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 2 OUT3	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 2 OUT4	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 3 IN1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 3 IN2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 3 IN3	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 3 IN4	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 3 OUT1	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 3 OUT2	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 3 OUT3	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 3 OUT4	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 4 IN1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 4 IN2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 4 IN3	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 4 IN4	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EM DIESEL GEN BUILDING 4 OUT1	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 4 OUT2	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 4 OUT3	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EM DIESEL GEN BUILDING 4 OUT4	Point	89.2	100%/24h	60.8	70.9	83.4	82.8	83	83.2	66	50.9
EMERCENCY GEN BUILDING 1 EX2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERCENCY GEN BUILDING 2 EX2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERCENCY GEN BUILDING 3 EX2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERCENCY GEN BUILDING 4 EX2	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERGENCY GEN BUILDING 1 EX 1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERGENCY GEN BUILDING 2 EX 1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERGENCY GEN BUILDING 3 EX 1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9
EMERGENCY GEN BUILDING 4 EX 1	Point	105.2	100%/24h	78.8	84.9	99.4	100.8	99	95.2	88	78.9